

**Government of Bihar**  
**Public Health Engineering Department**  
**Water Quality Report**

**District:- Nawada**      **Division Name:- Public Health Engineering Division, Nawada**

Sample Code:- 1372-1323

Sample Collected by:- Budhayan Public School, (JE Ashwani Kumar)		Date of Sampling :- 05-08-2025																
Sl. NO.	Block	Panchayat	Name of School	Scheme	Test Report													Remarks
					pH	Turb.	EC	TDS	TH	Ca	Mg	CI	ALK	F	Source of water			
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17		
1	Kashichak	Kashichak	Budhayan Public School, Parwati	Tubewell	6.9	0.92	565	367	180	64	21	50	190	0.82	Tap Water	Tested Parameters are within Permissible Limit.		
2	Kashichak	Kashichak	Budhayan Public School, Parwati	RO	6.72	0.17	88	57	30	16	5	12	35	0.14	Filter Water	Tested Parameters are within Permissible Limit.		
<b>Desirable Limit* (IS10500:2012)</b>					6.5	1.0	500	500	200	75	30	250	200	1.0				
<b>Permissible Limit* in absence of</b>					8.5	5.0	2000	2000	600	200	100	1000	600	1.5				

*Handwritten Signature*  
 05/08/2025  
 Chemist

P.H. Division, Nawada



*Handwritten Signature*  
 05/08/2025  
 Assistant Engineer

P.H. Sub, Division, Nawada

*Handwritten Signature*  
 05/08/2025  
 Executive Engineer

P.H. Division, Nawada

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE

Ref. No. 1644

Date: 7/08/25

It is certified that an inspection team headed by **Amar kumar (Chemist)** (Name of officers with designation) from P.H.D Nawada PHED inspected the **Budhayan Public School, Parwati, Kashichak, Nawada** Address:- Parwati, Kashichak, Nawada (Name and address of the school) on -06/08/2025(Date of inspection) and on the basis of Water Test Report (Attached) report no – DL/NWD/1322-1323 Dated :-07/08/2025 of District Level Water Testing Laboratory (PHED Lab) certified that the **Budhayan Public School, Parwati, Kashichak, Nawada** (Name Of School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintain the hygienic sanitation condition in the school building & campus as per norms prescribe by the central/state/U.T. Govt.

This certificate is valid till Six months (As per date of issue).

Signature with Seal:

Name:- Sujeet Kumar

Designation: Executive Engineer

Name & Address of the

Office/Department:

To,

The

**Budhayan Public School, Parwati, Kashichak, Nawada** Address:- Parwati, Kashichak, Nawada

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/PHED Lab/local bod